



Utility Systems Integration

Wind Farm Monitoring

National Wind Technology Center

Yih-huei Wan

November 17, 2004



Presentation Topics

- What Are the Issues
- What Does This Program Try to Achieve
- Approaches
- What We Have Learned
- What Are Still Needed
- On Going Effort for FY2005
- Industry Collaborations

What are the Issues?

- Rapid increase of wind power in the grid and more utilities are connecting wind power in their systems
- Compared to conventional generating technologies, utilities still lack experience in operating and planning for wind; there are misconceptions about wind power behavior
- Utilities and ISOs need to know how wind power will affect the grid operations (ancillary services requirements, reserves, power quality issues, etc.)
- Real wind farm data needed for system operational studies (long-term) and for model validation (high-frequency); but the required data are often not available—either not archived or proprietary



What Does This Program Try to Achieve?

- Collect long-term, actual output data from commercial wind farms to characterize the real behavior of wind power
- Record high-frequency voltage and current data at wind farms to analyze the transient characteristics of large wind farms
- Collect high-frequency data for wind farm dynamic model validation
- Maintain the database and make it available for industry for wind integration and impact studies while protecting sensitive business information




Approaches

- Work with wind plant owners/operators and host utilities to record 1-second wind power data at 3 wind farms in Iowa and Minnesota
- Collaborating with ERCOT to record 1-second wind power data from 4 wind farms in Texas
- Collaborating with Western Farmers Electric Cooperative (WFEC) to record 10-minute wind power data from 1 wind farm in Oklahoma
- Collect event-triggered, 10-second V and I waveforms at sampling rate of 120 Hz from 4 Texas wind farms

Wind Farm Monitoring Project


(Total capacity ~940 MW)



Example Wind Farm Power Data

1-Min Average Wind Power

Indian M (82.5 MW) King Mtn (79.3 MW)
Trent M (150 MW) TWPP (35 MW)



Wind Power Ramping

Average Wind Power Ramping: 0.5 MW/min or 0.5%/min

Example European Grid Code ramping limits:

- 30 MW/min or 100 MW/10 min
- 5% rated/min

Typical power plant ramping capabilities:


- Hydro 50%~100% per minute
- Combustion turbine 10%~20% per minute
- Coal plant 3%~5% per minute

Load changes:

Standard deviation of 10-min load changes 60 MW (9 GW system)



Example Disturbance Data





What We Have Learned

- Short-term fluctuations are confined in narrow range;
- Step changes and ramping rates are more influenced by the size of the plant (number of turbines); they appear to be independent of plant locations and turbine types
- Ramping caused by wind speed changes are seldom severe
- Temporal and spatial diversity of wind speed reduce the variability of wind power
- Simple scaling of output from small wind power plant to match output of large wind project exaggerate fluctuation and ramping behavior
- Availability of utility system information continues to be an issue in the system impact studies



What Are Still Needed

- Collect and develop a high-frequency database (wind farm output and system conditions) for wind farm dynamic model validation
- Collaborate with utility stakeholders to assemble synchronized system data (load, generation, interchange, and ACE) to assess the wind power impact on system operations



On Going Efforts for FY2005



- Capture transient event data for wind farm model validation
 - Develop high speed data acquisition system
 - Work with PacifiCorp to collect Wyoming Wind Energy Center turbine and plant responses under fault conditions (NREL will monitor 3 turbines inside the plant, PacifiCorp will monitor the plant at the interconnection point)
- Work with utility partners to collect system data along with wind power data for system impact analysis
 - Work with Western Farmers Electric Cooperative in Oklahoma to save system load, frequency, ACE, interchange, and generation data along with Blue Canyon Wind Power plant output
- Continue the effort to add wind power plants in different regions to the monitoring program for better characterization of wind power spatial diversity



On Going Efforts for FY2005

(continued)



- Wind power primer for utility planning engineers
- Use AREVA T&D system simulation software (DTS) and work with utility partners to analyze wind power ancillary service requirement (possible partner SMUD)



Industry Collaborations



- System Impact study
 - Xcel Energy northern system could include 1,500 MW of wind power by 2010 (currently 470 MW)
 - Wind impact study required by Minnesota Legislature; Minnesota Department of Commerce responsible for the study; EnerNex performed the work; 1-second Lake Benton data were used
 - Report available at http://www.state.mn.us/mn/externalDocs/Commerce/Wind_Integration_Study_092804022437_WindIntegrationStudyFinal.pdf
 - Generation reliability impact: average capacity value 25.9% of nameplate (388 MW out of 1,500 MW)
 - Integration costs: additional regulation duty \$4.37/MWh
 - Load following effect: standard deviation of hourly deviation increases from 53.4 MW to 64 MW with 1500 MW of wind capacity



Industry Collaborations

(other studies)



- EPRI/DOE Energy Storage Handbook (Technology Insights)
- Wind power impacts on electric power system operating costs (NREL, Milligan)
- WAPA rate study (WAPA/ORNL/NREL)
- S&C Electric Company (Energy storage device for wind)
- UT Austin
- Wind energy market value study (Energy and Environment Research)
- Wind Power Plant Behaviors: Analyses of Long-Term Wind Power Data

<http://www.nrel.gov/docs/fy04osti/36551.pdf>